



# ARC FLASH TESTING

CEI EM 622271-200:2005 item 6.106

**INFRARED WINDOWS** 

MODELS: JIT50; JIT75









LAB N° 0935





**TEST REPORT** 









Nº RP LS 12/172

CUSTOMER:

Gimi - Ouadros Elétricos

Estrada Portão da Ronda, 3.530

Jd. Revista - Suzano/SP

Brazil

DEVICE UNDER TEST:

A.C. Metal-enclosed Switchgear

TYPE:

Maggiore Max

PURPOSE OF THE TEST:

Type test

TEST PERFORMED ACCORDING TO:

CEI EN 62271-200: 2005 item 6.106

TEST PERFORMED AT:

Power Test Section of SVEPPI Laboratory

Via Alessandro Volta, 34/A – 30030 Salzano (VE)

ITALY

LIST OF TESTS PERFORMED:

Arcing due to internal fault

RECEIPT'S DATE OF TEST OBJECT:

2012/07/26

PERIOD OF TEST:

2012/09/05 - 2012/09/06

TEST WITNESSED BY:

Mr. N. Graziano

Gimi – Quadros Elétricos

Mr. J. L. De Aravio

InfraPred

#### THIS TEST REPORT IS COMPOSED BY:

Nr. 32 Total pages

Nr. 05 Oscillograms

Nr. 02 Lists (Reported on Page 2) Nr. 04 Drawings (Reported on Page 2)

Siemens S.p.A. Laboratorio SVEPPI

The data necessary to permit repetition of the tests are contained in the document marked "TEST'S DOCUMENTATION" n. LS 12/172.

Issue

Charged of test

aboratory's manager

September 2012

Sandro Samartinaro

iuseppe Canonico

This Test Report is not a certificate of conformity, the results are referred only to the tested sample.

This document shall be reproduced only in its entirety. For partial reproduction written authorizations of SVEPPI is necessary.









N° RP LS 12/172

**MANUFACTURER:** Gimi - Quadros Elétricos Ltda

Estrada Portão da Ronda, 3.530

Jd. Revista - Suzano/SP

Brazil

InfraPred - Equipamentos para Manutenção Ltda

**SERIAL NUMBER OF DEVICE UNDER TEST:** MAG – 01/2012

#### RATINGS ASSIGNED BY MANUFACTURER OF DEVICE UNDER TEST


| Rated voltage   | 13.8           | $\mathbf{kV}$          |
|---|----------------|------------------------|
| Number of phases  | 3              |                        |
| Rated frequency   | 50/60          | Hz                     |
| Rated normal current  | 1250/2500      | $\mathbf{A}$           |
| Rated short-time withstand current (main and earthing circuits) | 31.5           | kA                     |
| Rated peak withstand current (main and earthing circuits)       | 82             | kA                     |
| Rated duration of short-circuit                                 | 1              | S                      |
| Rated internal fault  | 31.5           | kA                     |
| Rated duration of internal fault                                | 1              | S                      |
| Test of accessibility   | AFLR (Front, L | ateral and Rear sides) |

#### IDENTIFICATION OF DEVICE UNDER TEST

The drawings in the list "MAGGIORE MAX - 31,5kA/1s- 1250/2500A - 13,8kV" and in the list "Infrared Windows model JIT50-ARC and JIT75-ARP - 31,5kA/1s - 1250/2500A - 13,8kV" have been identified by SVEPPI Laboratory. The drawings have been returned to the customer.

The following drawings are included in this Test Report.

| Number        | Date       | Revision | <b>Pages</b> | Title                         |
|---------------|------------|----------|--------------|-------------------------------|
| New Maggiore  | 2012/06/18 | 00       | 1            |                               |
| M05           | 2012/06/18 | 00       | 1            |                               |
|               |            |          |              | CUBICULO EXTRAIVEL LSC2-B -   |
| MAGGIORE 31,5 | 2007/06/28 | 00       | 8            | MAGGIORE 15kV - NBI-95kV -    |
|               |            |          |              | 31,5kA - 1250/2500A           |
| JIT-75-ALPR   | 2012/03/21 | 0        | 1            | JANELA DE INSPEÇÃO JIT-75-ARP |



#### 1. ARCING DUE TO INTERNAL FAULT

#### 1.1. Purpose of the tests

The purpose of the tests was to assess the behaviour of the A.C. Metal-enclosed Switchgear under arcing stress due to internal fault as following described. The test object was tested with the thermographic investigation windows of InfraPred Equipamentos para Manutenção Ltda mounted.

#### 1.2. Performed tests

The A.C. Metal-Enclosed Switchgears type Maggiore Max under test was prepared and placed under a room simulated by a structure with the ceiling and two walls perpendicular to each other.











N° RP LS 12/172

#### 1.3.1. Arc initiation

The arc was initiated between phases on compartment of functional unit 2 (Figure 1), by means of a 0.5 mm diameter copper wire (see also Photo 2).

#### 1.3.2. Indicators

The indicators for observing the thermal effects of gases were arranged as indicated in Figure 1, according with CEI EN 62271-200: 2005 to verify the type AFLR accessibility on Front, Lateral and Rear sides (see also Photos 3-4, 6-7).

The indicators used during the tests were pieces of black cretonne (150 g/m $^2$ ), fitted in frames of steel having dimensions of about 150 mm x 150 mm.

During the test the InfraPred JIT75 thermographic investigation window was mounted. The window was not damaged, as can be seen in Photo 5, 9.

The conditions of the circuit breaker box after the test are visible in Photo 8.











N° RP LS 12/172

#### 2. TESTS RESULT

#### 2.1. Oscillograms table

| Oscillogram | Test current    |                | Duration | Note                                     |  |
|-------------|-----------------|----------------|----------|--|--|
| Nr.         | Peak value [kA] | RMS value [kA] | [s]      | Note                                     |  |
| 158953      | 73.8 (Phase T)  | 31.7           | 1.017    | Circuit breaker box of functional unit 2 |  |
| 158955      | 73.7 (Phase T)  | 32.0           | 1.017    | Omnibus box of functional units 2        |  |
| 158956      | 73.9 (Phase T)  | 31.7           | 1.015    | Circuit breaker box of functional unit 1 |  |
| 158958      | 73.9 (Phase T)  | 31.7           | 1.017    | Cables box of functional unit 1          |  |
| 158963      | 73.9 (Phase T)  | 31.8           | 1.019    | Cables box of functional unit 2          |  |









LAB N° 0935

N° RP LS 12/172

#### 5. PHOTOS



Photo 1 - Test arrangement



# **SIEMENS**







Photo 5 – Before test (InfraPred JIT75)



Photo 6 - After test



Photo 7 – After test



# **SIEMENS**







Photo 8 - After test



Photo 9 – After test (InfraPred JIT75)









LAB N° 0935



Photo 18 – Before test (InfraPred JIT50)









N° RP LS 12/172

2012/09/05 **AFTER TEST** 

Photo 21 – After test (InfraPred JIT50)

